

Earthing (Electrical Continuity)

Topraklama

All metal tray systems must have proper electrical continuity. However, to ensure safety, it is advisable to make an earth connection using a suitable conductor for each part of the system.

This cannot be done on painted or epoxy-coated trays without removing the protective layer at that point and at the join-points between the various lengths, which will inevitably lead to oxidation.

Without ensuring safety

Bütün kablo kanalı sistemlerinde elektriksel süreklilik sağlanmalıdır. Sistem güvenliğinin sağlanması açısından topraklama yapılması tavsiye edilir.

